



SEALING—INSTALL RUBBER O—RINGS OR GASKETS AROUND EACH PIPE (CASING CARRIER) TO PROVIDE CONTINUOUS WATER—TIGHT SEAL TO PREVENT EXPANSION AND CONTRACTION.

NOTE:  
SLED LENGTHS TO BE 75%  
OF PIPE LENGTHS

OPT: 1/2" GROUT OVER  
1 FOUR INCH BRICK  
COURSE AT EACH  
END OF CASING



PIPE I.D.	RUNNER SIZE
UP TO 12"	4" x 4"
15" - 21"	4" x 4"
24" - 30"	4" x 6"



**CITY of DELTA**  
360 MAIN STREET  
DELTA, CO 81416

## PIPE CASING & SLED DETAIL

DATE: DEC. 1998

SHEET W13 OF 13